

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7167-0822:115 Page 1 of 1

**CATEGORY:** Control Unit (Household)

**LISTEE:** Honeywell Protection Services, 2701 4th Avenue South, Minneapolis, MN 55408  
Contact: \*Bob Hodgson \*(847) 797-4403

**DESIGN:** Model 5501. Refer to listee's data sheet for detailed product description and operational considerations. Basic components:

5501	Control/Communicator Panel
120	Security Control System Keypad
D1625	Transformer
D126	Rechargeable Battery
D4103	Enclosure

**INSTALLATION:** In accordance with listee's printed installation instructions and applicable codes and ordinances.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as a household control unit for use with separately listed compatible initiating and indicating devices.

**NOTE:** Burglary and other non-fire functions were not examined.

**NOTE:** Formerly 7165-0822:115

**XLF:** 7167-0801:106

\*Rev. 08-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**AUGUST 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager